

Well Report
Well No. 3

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157 Austin, Texas 78711 (512) 463-7880 FAX (512) 463-8616
Toll free (800) 803-9202
Email address: water.well@license.state.tx.us

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

WELL REPORT

1) OWNER

A. WELL IDENTIFICATION AND LOCATION DATA

Name Prairie Pointe Estates Well 3	Address 2000 S. IH35 Suite #Q11	City Round Rock	State Texas	Zip 78681
--	---	---------------------------	-----------------------	---------------------

2) WELL LOCATION

County Burnet	Physical Address SW corner of CR 274 & 276	City Bertram	State Texas	Zip 78654
-------------------------	--	------------------------	-----------------------	---------------------

3) Type of Work

New Well Deepening
 Reconditioning

Lat. 30° 45 02 Long. 098° 59 59 Grid # 57-16-9

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

5) N↑

6) Drilling Date

Started **1-27-21**
Completed **1-27-21**

Diameter of Hole		
Dia. (in)	From (ft)	To (ft)
10	0	19
6 1/2	19	510

7) Drilling Method (check) Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

From (ft)	To (ft)	Description and color of formation material
0	1	Top Soil
1	32	Yellow Limestone
32	174	Gray Limestone
174	190	Brown Limestone
190	233	Gray Limestone
233	280	Gray Limestone & Shale Strips
280	310	Gray Sandstone
310	340	Gray Sandstone & Shale Strips
340	381	Gray Sandstone & Sand Strips
381	386	White Limestone
386	427	Gray Sandstone & Sand Strips
427	443	Gray Limestone

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____
If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data					
Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
4 1/2	N	Plastic	0	510	
	N	Screen	470	490	.032
	N	Screen	390	430	.032

9) Cementing Data
Cementing from **0** ft. to **20** ft. # of sacks used **6**
_____ ft. to _____ ft. # of sacks used _____
Method Used **Hand Poured**
Cementing By **Tom Arnold Drilling**
Distance to septic system field or other concentrated contamination **150** ft.
Method of verification of above distance **Tape Measure**
***None Within This Distance Found**

13) Plugged

Well plugged within 48 hours

Casing left in well:		Cement/Bentonite placed in well:		
From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

10) Surface Completion
 Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

14) Typepump None

Turbine Jet Submersible Cylinder
 Other _____

Depth to pump bowls, cylinder, jet, etc., _____ ft.

15) Water Test

Typetest Pump Bailer Jetted Estimated
Yield: **20** gpm with _____ ft. drawdown after _____ hrs.

11) Water Level
Static level _____ ft. below Date / /
Artesian Flow _____ gpm. Date / /

16) Water Quality

Did you knowingly penetrate any strata which contain undesirable constituents?
 Yes NO If yes, did you submit a REPORT OF UNDESIRABLE WATER?
Type of water _____ Depth of Strata _____
Was a chemical analysis made? Yes No

12) Packers Type Depth
Shale Trap **470',390',290',20'**

Company or Individual's Name (type or print) Tom Arnold Drilling		Lic. No. 2096	
Address 2750 South A. W. Grimes Blvd.	City Round Rock	State Texas	Zip 78664
Signature _____	Date / /	Signature _____	Date / /
Licensed Driller/Pump Installer		Apprentice	

